

## City of Burlington Department of Public Works

Water Resources Division 234 Penny Lane Burlington, VT 05401 802.863.4501 P www.burlingtonvt.gov/DPW

Chapin Spencer PUBLIC WORKS DEPARTMENT DIRECTOR

Megan Moir WATER RESOURCES DIVISION DIRECTOR

November 26, 2019

John Caulo LANDPLAN 61 Central Ave Burlington, VT 05401

Re: Water and Wastewater Allocation Request for Change of Use at 266 Queen City Park Road (Burton Campus)

Dear John,

This letter is to inform you, your client, the State of Vermont Environmental District and other interested parties that the City of Burlington's water and wastewater facilities have sufficient capacity to handle flows associated with a Performing Arts Venue at the above address. We have reserved 7,500 gpd (gals/day) for both water and sewer. This is based on a maximum of 1500 persons at 5 gpd per person.

Wastewater flow from this area is treated at our Main Wastewater Plant on Lavalley Lane. It is important to note that this letter only addresses dry weather treatment plant and not organic loading or wet weather collection system capacities. Our collection system serving this area is a combined sewer system (CSS) and our efforts over many years has been to remove stormwater input to the CSS. We are in draft stages of a combined sewer policy that eventually will require customers connected to our combined sewer to either remove stormwater input or offset increased wastewater baseflow. We reserve the right to contact you/your client regarding a potential offset project after a formal policy has been approved.

This letter is good for three (3) years from the date of writing. If this letter is not filed with the proper offices, or if the proper permits are not obtained within that year, you will need to reapply. Any changes in flow estimates or property usage also requires reapplication. Please feel free to call me at 343-0125 if you have any questions.

Sincerely,

Steve Roy, P.E. Project Engineer

Burlington Public Works

queencity266\_cap